



NOTES

3, 4, etc. 10 AMP DIMMER CHANNEL (ON BRIDGES TERMINATING IN SINGLE 15A S/O, ON FLYS & DIPS BOXES TERMINATING IN DOUBLE 15A S/O, IN PATCH PANEL TERMINATING IN DOUBLE 15A S/O. 20 AMP DIMMER CHANNEL SUB-CIRCUIT TERMINATING IN DOUBLE 15A S/O. 2" PROTECTED BY LOCAL 10A FUSE.

12, 13, etc. 20 AMP DIMMER CHANNEL (ON FLYS & DIPS BOXES TERMINATING IN SINGLE 32A S/O (L/D 2" SEPARATELY FUSED DOUBLE 15A S/O IN PATCH PANEL TERMINATING IN 2" SEPARATELY FUSED DOUBLE 15A S/O. STATEMENT FUSED DOUBLE 15A S/O. P1, P2, etc. SINGLE 15A S/O ON BRIDGES; PAIR OF 15A S/O ON LADDERS, TERMINATING IN SINGLE 15A PLUS ON TAIL IN PATCH PANEL.

PS1, PS2. 32A INDEPENDENT S/O FOR FOLLOW SPOT, WITH LOCAL ISOLATOR.

A, B, etc. SINGLE 15A INDEPENDENT S/O SWITCHED FROM CONTROL ROOM FOR EFFECTS.

SM'A etc. SINGLE 15A INDEPENDENT S/O SWITCHED FROM PLANT CORNER, FOR EFFECTS.

W1, W2 etc. DOUBLE 15A INDEPENDENT S/O SWITCHED FROM PLANT CORNER, FOR WORKING LIGHTS.

TD. 10 AMP HOUSE LIGHT SUB-CIRCUIT FOR USE AS TRUSS-DRESSING LIGHT, TERMINATING IN PATCH PANEL IN DOUBLE 15A S/O.

13A. SINGLE 15 AMP BREAK MAINT S/O WITH LOCAL FUSE.

N.B.: DIPS CHANNELS 89-94 & 98-103 HAVE LOCAL CHANGE-OVER SWITCHES TO DIVERT OUTPUT TO ALTERNATIVE LOCATIONS (FORESTAGE & FLOATS).

(Box 1) etc. S/O BOX IDENTIFICATION NUMBERS AS SHOWN ON OTHER PLANS (FLYS & STAGE LEVEL BOXES ONLY).

FOR S/O BOX DETAILS SEE 8329/0512.

FOR S/O BOX MOUNTING LOCATIONS SEE 8329/0551, 8329/0552, 8329/053, & 8329/054.

DIPS USR (Box 15)
116-119
66 & 111
13.3

FLYS ER 2 (Box 6)
85-97
N.E.K., 13.3

FLYS ER 1 (Box 6)
80-81
T & V, 13.3

DIPS DSR (Box 11)
98-101
& S/O TO FORESTAGE
& S/O TO FLOATS
104-105, (10)
CC & DD, 13.3

FORESTAGE SR (Box 12) (SIMILAR LOCUS - 2" LOCATIONS)
98-101, Z, 13.3

FLOATS SR (Box 10)
102-103, SM'A, SM'B

SR LADDER

P21	P21
P22	P22
P23	P23
P24	P24
K	
13A	

22
21
20
19
18
17
16
15
14
13
12
11
10
9
8
7
6
5
4
3
2
1
HOUSE CURTAIN

LINE PLAN
(INSTALLED OUT SIZES)

DIPS DSL (Box 8 - WITHIN FACILITIES PANEL)
89-92 & S/O TO FORESTAGE
93-94 & S/O TO FLOATS
95-96, (9)
AA & BB, 13.3

FORESTAGE SL (Box 9) (SIMILAR BOXES - 2" LOCATIONS)
89-92, Y, 13.3

FLOATS SL (Box 10)
93-94, SM'A, SM'B

SL LADDER

P17	P17
P18	P18
P19	P19
P20	P20
S	
13A	

PATCH PANEL
P1 - P24
INTS
(41) - (47)
35-42
TD